



广州高铁计量检测股份有限公司

Guangzhou Gaotie Metrology and Test Co., Ltd.



中国认可
国际互认
校准
CALIBRATION
CNAS L2203

证书编号:
Certificate No.



GTC01819006009-001

校准证书

CALIBRATION CERTIFICATE



委 托 方
Client

Hitachi Soe Electric & Machinery Co. Ltd.

地 址
Address

Building No. 1, Aung Chan Thar Housing Estate, East Shwe Gondine Road, Bahan Township, Yangon, Myanmar

样 品 名 称
Description

Transformer Turns Ratio Tester

型 号 / 规 格
Model/Type

JYT (A)

编 号
Serial No.

04193211

制 造 商
Manufacturer

Baoding Kingrun Technology Co., Ltd.

接 收 日 期
Date of Receipt

2019 - 09 - 02



批准人
Approved by

吕文龙

吕文龙

审核人
Checked by

李镇浩

李镇浩

校准员
Calibrated by

湛耀荣

湛耀荣

校准日期
Date of Calibration

2019 - 09 - 03

建议再校日期
Date of next Calibration

2020 - 09 - 02



扫一扫查真伪

地址: 广州市番禺区大石街南大公路礼村鸿图工业园A1幢1、2楼

Add: 1-2F, Building A1, Hongtu Industrial Park, Licun Road, Nanda Road, Dashi Street, Panyu District, Guangzhou, Guangdong, China

电话 (Tel): 020-39932518

传真 (Fax): 020-34797200

邮编 (Post Code): 511430

公司网址 (Web): <http://www.gaotie.com>

微信公众号 (WeChat): 广州高铁计量



说 明

DIRECTIONS

证书编号:



Certificate No.

GTC01819006009-001

第 2 页 共 4 页

Page of

1. 本公司质量管理体系符合ISO/IEC 17025: 2005 标准的要求。

The quality system is in accordance with ISO/IEC 17025:2005.

2. 本公司所出具的数据均可溯源至国家计量基准和国际单位制(SI)。

All data issued by this laboratory are traceable to national primary standards and SI Units.

3. 本次校准的技术依据:

Reference documents for the Calibration:

JJG 970-2002 《变压比电桥检定规程》

JJG 970-2002 《Verification Regulation of Transformers Turn Ratio Test Sets》

4. 本次校准所使用的主要计量标准器具:

Major standards of measurement used in the calibration:

设备名称 / 型号 Name of Equipment / Model	编 号 Serial No.	证书编号/有效期 Certificate No. /Due date	计量特性 Metrological/Characteristic
感应分压器 HJF4 Induction divider	GT/SB-D316	DCH201830022/ 2020-01-07	0.005级
三相组合电压互感器 TR-II Three-phase combined voltage transformer	GT/SB-D102	DCH201831211/ 2020-12-27	0.01级

校准地点: 本公司电磁室 Electromagnetic Lab

Place of the Calibration:

校准环境条件:

温度: 23 °C

相对湿度: 56 %RH

Environmental of the Calibration Temperature

Relative humidity

注:

Note: 1.The results relate only to the items calibrated.

1. 本证书校准结果只与受校准仪器有关。

2.This certificate shall not be reproduced except to full, without the written approval of our laboratory.

2. 未经本公司书面批准, 不得部分复制此证书。

3.This certificated shall not be valid without stamp of our institute.

3. 此证书无本公司盖章无效。

4.This certificate No. is according to the record No.

4. 证书与原始记录同号。



证书编号:

Certificate No.



GTC01819006009-001

第 3 页 共 4 页

Page of

校准结果

RESULTS OF CALIBRATION

1.Appearance and general examination:Passed

2.Variable Ratio Indicator Error Calibration:

Standard value	Indication value	Error	Permissible error	Result (Pass/Fail)
10	9.9972	-0.0028	± 0.0200	P
20	19.988	-0.012	± 0.040	P
50	49.991	-0.009	± 0.100	P
100	99.967	-0.033	± 0.200	P
200	199.89	-0.11	± 0.40	P
500	499.99	-0.01	± 1.00	P
1000	999.90	-0.10	± 2.00	P

3.Three-phase connection level calibration:

Phase	Group	Standard value	Indication value	Error	Permissible error	Result (Pass/Fail)
AB	Y/y0	10	10.013	0.013	± 0.020	P
	Y/y6	10	10.000	0.000	± 0.020	P
	D/d0	10	9.9972	-0.0028	± 0.0200	P
	D/d6	10	9.9967	-0.0033	± 0.0200	P
	Y/d5	10	9.9995	-0.0005	± 0.0200	P
	Y/d11	10	9.9996	-0.0004	± 0.0200	P
	D/y5	10	9.9968	-0.0032	± 0.0200	P
	D/y11	10	9.9972	-0.0028	± 0.0200	P
BC	Y/y0	10	10.016	0.016	± 0.020	P
	Y/y6	10	10.000	0.000	± 0.020	P
	D/d0	10	9.9971	-0.0029	± 0.0200	P
	D/d6	10	9.9966	-0.0034	± 0.0200	P
	Y/d5	10	9.9997	-0.0003	± 0.0200	P
	Y/d11	10	9.9997	-0.0003	± 0.0200	P
	D/y5	10	9.9969	-0.0031	± 0.0200	P
	D/y11	10	9.9971	-0.0029	± 0.0200	P



证书编号:

Certificate No.



GTC01819006009-001

第 4 页 共 4 页

Page of

校准结果

RESULTS OF CALIBRATION

CA	Y/y0	10	10.001	0.001	± 0.020	P
	Y/y6	10	10.000	0.000	± 0.020	P
	D/d0	10	9.9971	-0.0029	± 0.0200	P
	D/d6	10	9.9968	-0.0032	± 0.0200	P
	Y/d5	10	9.9998	-0.0002	± 0.0200	P
	Y/d11	10	9.9995	-0.0005	± 0.0200	P
	D/y5	10	9.9970	-0.0030	± 0.0200	P
	D/y11	10	9.9972	-0.0028	± 0.0200	P

Conclusion: It meets the technical requirements of the calibrated projects.

Remarks: 1.The extended uncertainty in this report is multiplied by the standard uncertainty by the inclusion factor K when the inclusion probability is about 95%

$U_{rel} = 0.02\%$ ($k=2$)

2.Based on JJF 1059.1-2012 Evaluation and Expression of Uncertainty in

(Blank below)